

MBK DHP-60 has been converted to CPC control

Existing MF88AO Board	
Inputs Address #7	
1	Outdoor DEW
2	Outdoor temp
3	Pre-Cool LAT A&C Temp
4	Pre-Cool LAT B&D Temp
5	DH Wheel LAT Temp
6	Space Temp
7	Inside Dewpoint
8	Inside Humidity
Output Board Address# 9	
1	Supply Fan #1
2	React Fan #1
3	Condenser Fan #1
4	Condenser Coil #1
5	Compressor #1
6	Compressor #2
7	Desiccant Wheel Start
8	Condenser Coil #1
Analog Output Board Address# 3	
1	Supply Fan #1 Speed
2	React Fan #1 Speed
3	Condenser Fan #1 Speed
4	

Existing 16AI Board	
Address #8	
1	Building Pressure
2	React In Temp
3	React Out Temp
4	Supply RH
5	React Filter Diff Pressure
6	Pre-Cool Filter Diff Pressure
7	Wheel Diff Pressure
8	Supply Temp
9	Return Air Temp
10	Main Power Loss Relay
11	Supply Air Smoke Detector
12	Return Air Smoke Detector
13	Service Access Door Switch
14	Pre Cooling Coil Pan Overflow Switch
15	Return Air Dirty Filter Switch
16	React Air Dirty Filter Switch

16AI Board	
Address #9	
1	Supply fan proof
2	Compressor #1 Current Switch
3	Compressor #2 Current Switch
4	Compressor #1 Low Pressure Switch
5	Compressor #2 Low Pressure Switch
6	Compressor #1 HP Transducer
7	Compressor #2 HP Transducer
8	Condenser Fan #1 Motor Proof
9	
10	Desiccant Wheel Moving Switch
11	Desiccant Wheel Starter Aux
12	Cond Coil #1 Damper Feedback
13	Cond Coil Damper Feedback
14	
15	
16	

## Controls Change Notification

- These Air2O units have been converted from the ALC OEM Controls to CPC controls.
- These units can be accessed thru the Building Controller.
- Any reference to the OEM controller in the IOM and Control Wiring plans to be ignored.
- For controls support contact: 855-688-6063 Controls@seer2.net